




Ref. No. : 83/STC/X/2014



MEASUREMENT RESULT

Measurement Date : 20 October 2014
Material : Reflecto Metal
Thickness : 400 micron
Coating : Zinc aluminium spandek 0.4 mm
Dry Density : ± 400 gram / m²
Method : Reverberation Chamber (Alpha Cabin- Room Volume 19m³)



af



Transmission Loss

Frequency (Hz)	STC - 22	Transmission Loss (dB)
125	6	17
160	9	15
200	12	13
250	15	15
315	18	16
400	21	14
500	22	18
630	23	18
800	24	21
1000	25	22
1250	26	24
1600	26	26
2000	26	26
2500	26	27
3150	26	26
4000	26	28

Bandung, October 22nd 2014

Head of Laboratory



Dr. Joko Sarwono

NIP. 132 130 045